



UNITED TECHNOLOGIES CARRIER

Commercial Division
Carrier Corporation

BULLETIN: CA-SB-19-C-71-55
DATE: 5/7/71
PAGE: 1 OF: 1

SERVICE BULLETIN

SUBJECT:

COOLER AND CONDENSER WATER CAPACITIES, 19C

SUPERSEDE
BULLETIN:

DATE:
PAGE: OF:

Installation, repair and service and equipment referenced in this Service Bulletin should be undertaken only by qualified persons. Carrier Corporation (1) makes no representations or warranties, expressed or implied, concerning the accuracy, completeness or right to use the information contained herein, and (2) disclaims all liability for injuries, damages, infringements and other losses which may arise on account of, or which may result from, the use or application of any information, method or apparatus disclosed herein.

PURPOSE

To advise of heat exchanger water capacities.

MACHINES AFFECTED

All 19C, 19CB, 17CA, and 17CB machines.

INFORMATION

Tables 1 and 2 give the cooler and condenser water capacities in gallons. This information is useful to help figure the correct concentrations for acid cleaning.

Heat Exchanger Size	Water Capacity (gal)	
	Cooler	Condenser
11	156	180
13	163	190
14	170	240
15	176	250
16	245	320
17	260	335
18	300	400
19	345	415
20	455	550
21	630	690
22	665	725
23	695	-
24	-	810

Vessel Size Cooler or Condenser	Water Capacity (gal)
	Cooler or Condenser
13	180
14	200
15	210
16	255
18	267
20	280