

INSTRUCTIONS



Carrier

A United Technologies Company

99TA510010

Instruction Sheet Number: **99TA510010**

99TA510010 (for RCD use only)


Description: FLOW SWITCH KIT

Author: Mike Wasner

Date: June 6, 2007

Part Number: TH70400612

NOTE: These instructions pertain to 30XA units built prior to serial number SN3505Q ONLY.



- 1) Connect the new cable to flow switch.
- 2) Route cable same as existing cable. Cable will be too long for some units. Bundle excess length and tie up with wire ties.
- 3) Make connections in control box per the diagrams below. Connections will be the same as existing except for CWFS-4.

