



# LONG-TERM STORAGE PERIODIC CHECKLIST AND LOGS YIA, YPC ABSORPTION CHILLERS

**SERVICE POLICY & PROCEDURES**

Supersedes 50.20-CL4 (806)

Form 50.20-CL4 (1015)

CUSTOMER: \_\_\_\_\_

JOB NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

LOCATION: \_\_\_\_\_

PHONE: \_\_\_\_\_

CUSTOMER ORDER NO: \_\_\_\_\_

JCI TEL NO: \_\_\_\_\_

JCI ORDER NO: \_\_\_\_\_

JCI CONTRACT NO: \_\_\_\_\_

CHILLER MODEL NO: \_\_\_\_\_

UNIT SERIAL NO: \_\_\_\_\_

The work (as checked below) is in process and will be completed by: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
Month Day Year

Failure to comply with these requirements will render any written or implied YORK warranty null and void.

### A. SUPPLEMENTARY DOCUMENTATION

The following documentation is required to FULLY COMPLY with the long term storage requirements.

- a. Long Term Storage Requirements - GENERAL (refer to Form 50.20-NM1)
- b. Long Term Storage Requirements - LONG -TERM STORAGE FIELD PREPARATION (YIA, YPC) (refer to Form 50.20-NM4)

### B. CHECKS

#### Monthly Checks

1. Visually inspect chiller for damage.
2. Visually inspect piping and connections for signs of leakage.
3. Verify valve caps and water nozzle protective caps are tightly in place.
4. Check shell-side and water-side nitrogen pressure charges at 5 psi, or at the factory charge mark. Note that small fluctuations are normal due to changes in temperature. If pressure is lost, notify YORK service immediately so the leak can be found and repaired in a timely fashion

#### Quarterly Checks

None

#### Semi Annual Checks

None

#### Annual Checks

Unwrap all electrical cabinets and install new Vapor Emitters (YORK p/n 026-37705-000) Reseal.

**MONTHLY**

		NITROGEN CHARGE (PSIG)						
		SHELL SIDE SINGLE PIECE SHIPMENT	SHELL SIDE TWO PIECE SHIPMENT		TUBE SIDE			
		Shells	Abs/Evap	Gen/Cond	Absorber	Evaporator	Generator	Condenser
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								
Date								
Initial								

NOTE: If the unit is not a split then only use the columns that are applicable to the unit.

**ANNUAL**

Date	
Initial	

